

Questions and Responses

C003688

Cesspool Services in Long Island

No.	IFB Section	IFB Page	Question	Response																																										
1			Good afternoon, can you please send me the previous bid results. Thanks.	<p>The previous awarded bid results are as follows:</p> <table border="1"> <thead> <tr> <th></th> <th>Service</th> <th>Estimated Gallons</th> <th>x</th> <th>Price per Gallon</th> <th>=</th> <th>5 Year Grand Total</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>Sewage Pumping</td> <td>204,000</td> <td></td> <td>\$.40</td> <td></td> <td>\$81,600.00</td> </tr> <tr> <td>B</td> <td>Digester Pumping</td> <td>88,000</td> <td></td> <td>\$.43</td> <td></td> <td>\$37,840.00</td> </tr> <tr> <td>C</td> <td>Emergency/on-call</td> <td>40,000</td> <td></td> <td>\$.40</td> <td></td> <td>\$16,000.00</td> </tr> <tr> <td colspan="6">Yearly Total Cost to OPRHP (A+B+C)</td> <td>\$135,440.00</td> </tr> <tr> <td colspan="6">Grand Total Cost to OPRHP (Yearly Total x 5 Years)</td> <td>\$677,200.00</td> </tr> </tbody> </table>		Service	Estimated Gallons	x	Price per Gallon	=	5 Year Grand Total	A	Sewage Pumping	204,000		\$.40		\$81,600.00	B	Digester Pumping	88,000		\$.43		\$37,840.00	C	Emergency/on-call	40,000		\$.40		\$16,000.00	Yearly Total Cost to OPRHP (A+B+C)						\$135,440.00	Grand Total Cost to OPRHP (Yearly Total x 5 Years)						\$677,200.00
	Service	Estimated Gallons	x	Price per Gallon	=	5 Year Grand Total																																								
A	Sewage Pumping	204,000		\$.40		\$81,600.00																																								
B	Digester Pumping	88,000		\$.43		\$37,840.00																																								
C	Emergency/on-call	40,000		\$.40		\$16,000.00																																								
Yearly Total Cost to OPRHP (A+B+C)						\$135,440.00																																								
Grand Total Cost to OPRHP (Yearly Total x 5 Years)						\$677,200.00																																								
2	2.1	9	For grease trap pump-outs, what is the maximum # of feet of suction hose required from service truck to grease trap?	300 feet is the maximum length of suction hose required from service truck to grease trap.																																										
3	2.1	9	For services done one per week from May thru October - will vendor be permitted to negotiate the day of the week with NY State/Contact on site?	For weekly services May through October, service must occur on Friday.																																										
4	2.1	9	Weekly service from May thru October - is this 5/1 thru 10/31?	Correct, weekly service is required from May 1 through October 31.																																										
5	2.1	9	When on-site staff accompanies vendor, what is the minimum number of gallons to be removed from any structure-excluding interior grease traps?	The grease traps can be as small as 100 gallons, however onsite OPRHP staff will endeavor to ensure the entire 5,000 gallon truck leaves the visit full from other locations from around the park.																																										
6	2	9, 10, 11	What is the earliest the vendor can arrive for service in the morning?	8:00 AM is the earliest time a vendor can arrive for scheduled service.																																										
7	2	9, 10, 11	Excluding emergency services, can service be done on a Saturday or a Sunday?	Regular scheduled service can only take place Monday through Friday.																																										
8	Attachment 1	53	How should we price for items such as Line Jetting and Snaking? There is no line item even though the service is talked about in the Service Requirements	Pricing will be an hourly rate for jetting and snaking. Please see the attached Amendment 1 for the updated Attachment 1 - Bid Form.																																										
9	2	9	IFB calls for a Vactor truck, however there is no line item for pricing of the Vac Truck and no estimated tonnage. How should pricing be done for using a Vactor Truck and what is the estimated tonnage and amount of times Vac Truck is required	OPRHP anticipates approximately 3 Vac. Truck visits per year, approximately 10,000 gallons annually. Please see the attached Amendment 1 for the updated Attachment 1 - Bid Form.																																										